

PM10 Inlet head



AT/BP Sensor




Inlet Downtube





Inlet Heater  
Insulation Sleeve



**Met One BAM-1020**



Medo Pump  
& Pump Tube



Roof Flange

BX-305



Leak Check Valve



BX-808

VSCC Separator

Smart Heater Relay Module



Smart Inlet Heater

Step 1. Identify monitor components



Step 2. Skip this step

Step 3. Pass downtube through smart heater and into inlet receiver


Step 4. Skip this step

Step 5. Tighten the two (2) inlet receiver set screws

Step 6. Tighten the two (2) heater set screws

Step 7. Wrap heater insulation sleeve around heater body

Step 8. Connect smart heater to relay module




Step 9. Attach AT/BP sensor to downtube



Step 10. Insert the VSCC and PM10 inlet head onto downtube



Step 11. Route and insert air tubing from the Medo pump to back of BAM






Older configuration smart heater  
plugs directly into back of BAM

Step 13. Connect AT/BP sensor signal  
cable to terminals


BX-596 AT/BP Sensor	
Wire Color	Terminal Name
Yellow	Channel 6 SIG
Black/Shield	Channel 6 COM
Red	Channel 6 POWER
Green	Channel 6 ID
White	Channel 7 SIG



Step 12. Connect Medo  
pump 2-conductor signal  
cable to terminals




Step 13-16. Connect earth  $\equiv$   
gnd, plug-in Medo pump, heater  
relay module, and BAM unit to  
electrical outlet



## Post-Assembly Steps and Parameter Configurations

Filter Tape Loading Diagram



Verify the settings

Install the filter tape

Perform the self-test

Calibrate the ambient temperature, ambient pressure and flows

Perform a leak check

Perform a 72-hour zero test

Menu	Sub-Menu	Setting
SETUP > CLOCK	--	Verify that BAM clock is 2 minutes ahead of data logger clock
SETUP > SAMPLE	BAM SAMPLE	042 MIN
	RANGE	1.000 mg
	OFFSET	-0.015 mg
	CONC UNITS	µg/m <sup>3</sup>
	COUNT TIME	8 MIN
SETUP > CALIBRATE	SPAN CHECK	24HR
	FLOW RATE	0016.7
	CONC TYPE	ACTUAL
	FLOW TYPE	ACTUAL
	HEATER CONTROL	AUTO
SETUP > HEATER	RH Control	YES
	RH Setpoint	35%
	Datalog RH	YES (Chan 4)
	Delta-T Control	NO